



TERMINATION CABINET NOTES:

1. Mount cabinet on Type G cabinet pedestal. See ES-3C.
2. Use Type G cabinet foundation.

NOTES:

1. Telephone demarcation cabinet shall be furnished with mounting boards, outlet boxes, circuit breakers and outlet plates. Dimensions are nominal.
2. Telephone demarcation cabinet shall be installed with the back toward the nearest lane of traffic.
3. All conduits shall be bonded to the enclosure.
4. In unpaved areas, the top of foundation for the telephone demarcation cabinet shall be 6" above surrounding grade.
5. In sidewalks and other paved areas, top of foundation for the telephone demarcation cabinet shall be level with finished grade.
6. The steel pedestal, base plate, bolt circle and foundation for the telephone demarcation cabinet shall be the same as that shown for a Type 1-C Standard. Pedestal shall be 2'-1" to 2'-6" in length. Anchor bolts required shall be 3/4" ϕ x 1'-6" with a 2" - 90° bend. Four bolts required per cabinet.
7. Telephone demarcation cabinet shall be provided with a slip fitter to permit mounting on 4 1/2" outside diameter pedestal. Slip fitter shall be bolted to bottom of cabinet.
8. Telephone interconnect conductors shall be enclosed in a 3/4"C or larger conduit through the foundation. Type 4 conduit shall be used to separate telephone and power conductors in cabinets and pedestals.
9. Install circuit breaker inside the junction box. The circuit breaker should be operated externally without opening the junction cover.

COMPONENTS

- (A) Back mounting board
- (B) Shelf supports (2)
- (C) Junction box duplex outlet to backboard
- (D) Bottom shelf
- (E) Terminal block, 12 positions

FASTENER SCHEDULE

- 4 - 3/4" (length) wood screws
- 4 - 3/4" (length) wood screws
- 4 - 1/2" (length) wood screws
- 4 - 3/4" (length) wood screws

STATE OF CALIFORNIA
DEPARTMENT OF TRANSPORTATION
**ELECTRICAL SYSTEMS
(TELEPHONE DEMARCATION
CABINET, TYPE A)**

NO SCALE

ES-3D

DIST	COUNTY	ROUTE	POST MILES TOTAL PROJECT	SHEET NO.	TOTAL SHEETS

Jeffery G. McRae
REGISTERED ELECTRICAL ENGINEER
No. E14512
Exp. 6-30-06
ELECTRICAL
STATE OF CALIFORNIA

May 1, 2006
PLANS APPROVAL DATE

The State of California or its officers or agents shall not be responsible for the accuracy or completeness of electronic copies of this plan sheet.

To get to the Caltrans web site go to <http://www.dot.ca.gov>